



**FOUNDATION SLEEVE REQUIREMENTS:**

1. SLEEVE SHALL BE 4" SCHEDULE 40 PVC, AND SHALL EXTEND 3" MINIMUM BELOW FOOTING AND 3" MINIMUM ABOVE FLOOR SLAB OR STEM WALL.
2. SLEEVE MAY BE UTILIZED AS THE ELECTRICAL SERVICE CONDUIT WHEN STRUCTURE REQUIRES A 4" SERVICE.



**CITY OF BOULDER CITY, NV**  
**PUBLIC WORKS DEPARTMENT**  
**ENGINEERING DIVISION**

**STANDARD DRAWING**  
**ELECTRICAL REQUIREMENTS**

**ELECTRICAL SERVICE FOUNDATION SLEEVE**

CREATED BY:  
**C. CROFT**  
 ISSUE DATE:  
**12/15/15**  
 FILE NAME:  
**BC-ELEC-SLEEVE**  
 SHEET:  
**1 OF 1**